



GENERAL NOTES:

- 1. INSTALL 26"H x 19"D CABLE TRENCH, COMPLETE WITH CABLE DIVIDER.
- 2. CABLE TRENCH MUST PASS BETWEEN EXISTING STEEL STRUCTURE FOUNDATION AND PROPOSED P56 BREAKER FOUNDATION.

NOTES:

- 1. THIS WORK TO BE COMPLETED UNDER ADD ALTERNATE #3. CONTRACTOR WILL REMOVE EXISTING CABLE TRENCH, ONCE ALL ASSOCIATED CABLES HAVE BEEN ABANDONED, REMOVED, OR RELOCATED. ALL DISTURBED AREAS WILL BE REPAIRED AS NECESSARY TO MATCH EXISTING GRADE.
- 2. THIS WORK TO BE COMPLETED UNDER ADD ALTERNATE #3. CONTRACTOR WILL REMOVE OUTDOOR PANEL #1 AND #2 FOUNDATION AND CABINETS ONCE ALL ASSOCIATED EQUIPMENT HAS BEEN ABANDONED, REMOVED, OR RELOCATED.
- 1. INSTALL CONDUITS BETWEEN THE CABLE TRENCH AND EQUIPMENT BY THE MOST DIRECT ROUTE THAT WILL NOT INTERFERE WITH OTHER STRUCTURES OR EQUIPMENT. WHERE MULTIPLE CABLES ARE TO BE ROUTED BETWEEN THE CABLE TRENCH AND EQUIPMENT, COMBINE CABLES WITH LIKE USAGE (POWER, CONTROL, AND COMMUNICATIONS) AND INSTALL EACH GROUP IN A SINGLE OR MULTIPLE CONDUITS SIZED SO THAT THE CONDUIT FILL LIMITATIONS OF THE NATIONAL ELECTRIC CODE CHAPTER 9, TABLE 1 ARE NOT EXCEEDED.

						DESIGNED	AO
						DRAWN	AO
						CHECKED	PW
LTR.	DATE	REVISIONS	BY	APPRD.			



730 NE WALDO ROAD, GAINESVILLE, FLORIDA 32641 / (352) 377-5821
1100 CESERY BLVD - SECOND FLOOR, JACKSONVILLE, FLORIDA 32211 / (904) 744-5401

WAUCHULA SUBSTATION RESTORATION/EXPANSION
WAUCHULA, FLORIDA

CONDUIT AND CABLE TRENCH PLAN

CERTIFICATE OF AUTHORIZATION #1841 APPROVED BY	DATE AUG 2009	PROJECT NO. 07602-032-01
PHIL WEBER P.E. # 36601	SCALE 1"=8'	DWG. NO. E-17

RECORD DRAWING

By: RODGER V. WARREN
Date: OCT. 2010

Contract Name: POWER TOWN LINE CONSTRUCTION, LLC
Contract No.: 07602-032-01

Others which have not been verified: JONES EDMUNDS DOES NOT WARRANT THE ACCURACY OF THIS INFORMATION FOR ANY PURPOSES OTHER THAN FOR ITS ACCURACY OF COMPLIANCE WITH ANY FEDERAL OR STATE REQUIREMENTS. THIS INFORMATION MAY BE INCORPORATED INTO THIS DOCUMENT BASED ON THE INFORMATION PROVIDED.

Phil Weber
P.E. #36601
JONES EDMUNDS & ASSOCIATES, INC.